

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

N° 47695 – 20693

1. Unique identification code of the product-type:

**Isolating Device ISM-95
B11066; B11070;**

2. Type, batch, serial number or any other element allowing identification of the construction product as required by Article 11(4):

Each individual product is identified with a label containing the production date code and a name of the tester

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems

4. Name, registered trade name or trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

SeTec Sicherheitstechnik GmbH – Hauptstr.40a – D82229 Seefeld - Europe

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks in Article 12(2):

SeTec Sicherheitstechnik GmbH – Hauptstr.40a – D82229 Seefeld - Europe

6. System(s) of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System1

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

VdS Schadenverhütung GmbH – Amsterdamer Straße 172 – D50735 Köln

has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued following certificate of constancy of performance / certificate of conformity:

0786 – CPD - 20693

8. No European Technical Assessment has been issued for this product.

Not applicable

9. Declared performance

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below.

Essential Characteristics	Performance	EN 54-17: 2005/ AC:2007
Norminal activation conditions / Sensitivity and Performance under fire conditions	passed	n/a, 5.2
Operational reliability	passed	4
Durability of operational reliability, temperature resistance	passed	5.4, 5.5
Durability of operational reliability, vibration resistance	passed	5.9 to 5.12
Durability of operational reliability, humidity resistance	passed	5.6, 5.7
Durability of operational reliability, corrosion resistance	passed	5.8
Durability of operational reliability, electrical stability	passed	5.3, 5.13

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Mr Michael Burner, managing director

Seefeld, 01.07.2013



(signature)